

527 CMR: BOARD OF FIRE PREVENTION REGULATIONS

527 CMR 27.00: EMERGENCY AND STANDBY POWER SYSTEMS

Section

27.01: Purpose and Scope

27.02: Adoption by Reference

27.03: Modifications of Provisions of NFPA 110

27.01: Purpose and Scope

The purpose of 527 CMR 27.00 is to provide performance requirements for the installation, maintenance, operation, and testing of emergency power supply systems.

27.02: Adoption by Reference

For the purposes of 527 CMR 27.00, the provisions of NFPA standard No. 110, Emergency and Standby Power Systems, 2002 Edition, are incorporated by reference except for the modifications stated in 527 CMR 27.03

27.03: Modification of Provisions of NFPA 110

For the purpose of 527 CMR 27.00, the provisions of NFPA 110 shall be modified as follows:

Chapter 3 Definitions:

3.2.2 Authority Having Jurisdiction: The head of the fire Department.

3.2.6 Should: For the purposes of 527 CMR 27.00, it is to indicate “shall”.

REGULATORY AUTHORITY

527 CMR 27.00: MGL c. 148, §§ 10 and 28.

UNOFFICIAL COPY

527 CMR: BOARD OF FIRE PREVENTION REGULATIONS

NON-TEXT PAGE